




"STOP CORONA VIRUS Wash Your Hand/Wear Mask/Maintain Social Distance"


 Delhi Jal Board	DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL LABORATORY WATER TREATMENT PLANT NANGLOI, DELHI-110041	 D.J.B. Diary No. 402 Date 24/04/24 अमृत महोत्सव
--	--	--

Water sample collected from" M/S New Sainik International School, Plot No.14,15 & 28 to 37 , Vikas Nagar , Near Vikas Kunj , Vikas Nagar , New Delhi-110059 water testing vide challan no. 1450 dated 18.04.2024.

S. No.	Particulars	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	--	--	--	22.04.2024
2.	Date of analysis	--	--	--	24.04.2024
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	--	No Objectionable		No Object
5.	Turbidity	N.T.U.	1.0	5.0	0.6
6.	PH value	--	6.5	8.5	5.1
7.	Electrical Conductivity	µmho	--	--	Nil
8.	Total dissolved solids	mg/l	500	2000	500
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	mg/l	--	--	Nil
10.	Total Alkalinity	mg/l	200	600	125
11.	Total Hardness	mg/l	200	600	142
12.	Calcium Hardness	mg/l	--	--	Nil
13.	Magnesium Hardness	mg/l	--	--	Nil
14.	Calcium as Ca	mg/l	75	200	71
15.	Magnesium as Mg	mg/l	30	100	39
16.	Ammonia as N	mg/l	0.5	N.R.	0.2
17.	Nitrite as N	mg/l	--	--	Nil
18.	Nitrate as NO ₃	mg/l	45	N.R.	16
19.	Sulphate	mg/l	200	400	125
20.	Chloride	mg/l	250	1000	135
21.	Dissolved Iron	mg/l	0.3	N.R.	0.1
22.	Fluoride	mg/l	1	1.5	0.01
23.	Cyanide	mg/l	0.05	N.R.	<0.002
24.	Residual Chlorine	mg/l	0.20	1.0	0.1
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0	0	0

REMARKS: On the basis of above tested parameters, the sample S-1 can be use for drinking purpose.



Chemist


Asst. Chief Water Analyst
DELHI JAL BOARD
Govt. of N.C.T. Delhi
Quality Control Laboratory
Water Works, Nangloi, Delhi-41





MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SING VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2024/D- 195

Dated: 25/04/24

HEALTH CERTIFICATE

1. Name of the School New Sainik International School
2. School address Plot No.14, 15 & 28 to 37, Vikas Vihar, Near Vikas Kunj, Vikas Nagar, New Delhi-110059
3. No of shifts 01 (Morning) Timing 08:00 AM TO 1.30 PM
4. No of students:- Boys 344 Girls 211 Total 555
5. No of staff: - Gents 04 Ladies 26 Total 30

Accommodation provide for classroom as under:-

- Floor area in the classroom is sufficient /insufficient Sufficient
- Classes are well lighted/ ill lighted Well lighted
- Classrooms are well ventilated/ill ventilated Well ventilated
- Classes are kept/ not kept neat and clean Neat & clean
- Building/ classrooms require/ do not require white wash etc. not required
- Drinking water is wholesome/ not wholesome wholesome
- Latrine arrangement is sanitary/ insanitary Sanitary from health point of view

Note:- Valid for one year from the date of issue

25.4.24

Dy. Health Officer
West Zone

Dy Health Officer
West Zone
MCD

